# **PowerData Technologies**

The power to connect

**Product Datasheet** 

### P-PACK UNDERDESK UNITS



### **PRODUCT DESCRIPTION**

Underdesk power units with individually fused UK sockets, and master/individual switch options.

- Individually fused power sockets
- Complies with BS6396:2022
- 150mm earth lead to ring terminal
- BS5733 3<sup>rd</sup> party approval
- 3 pole connector input/output
- Daisy chain from one unit to another via the use of Inter leads

### **STANDARD PRODUCTS**

Part Code	No. of Power	Switch	Dimensions
P-Pack 2	2 x 5A sockets	n/a	236 x 42.5 x 62mm
P-Pack 2/2	2 x 5A sockets	2 x switches	236 x 46.7 x 62mm
P-Pack 3	3 x 3.15A sockets	n/a	285 x 42.5 x 62mm
P-Pack 3/1	3 x 3.15A sockets	Master switch	285 x 46.7 x 62mm
P-Pack 4	4 x 5A sockets	n/a	334 x 42.5 x 62mm
P-Pack 4/1	4 x 5A sockets	Master switch	363 x 46.7 x 62mm
P-Pack 4/4	4 x 5A sockets	4 x switches	398 x 46.7 x 62mm
P-Pack 6	6 x 3.15A sockets	n/a	464 x 42.5 x 62mm
P-Pack 6/1	6 x 3.15A sockets	Master switch	493 x 46.7 x 62mm


## **PowerData Technologies**

The power to connect

#### **INSTALLATION**

Underdesk units can be installed either into a wire basket cable management system, or directly to the under desk.

The unit has mounting brackets either end for either cable tying to a basket or screwing directly to a desk.



### **USAGE & MAINTENANCE**

Not to be used with products and appliances exceeding the rating of the socket (3.15A for a 3-way or 6-way, or 5A for a 2-way or 4-way) Fuses are 5x20mm and can be user-replaced.

To replace a fuse, disconnect the unit from the mains first.

To clean unit, disconnect from the mains, and wipe with a clean damp cloth

### **TECHNICAL SPECIFICATION**

Construction PVC extrusion, PVC sockets and fascias

Max voltage 250V Fuse rating 3.15A or 5A

Fuse size/type 5x20mm ceramic slow blow Mains connector 20A male 3-pole connector

Conformities BS 1363; BS 6396:2008; BS 5733; IEC60884-1:2006; UL 94V-0

Switch Single pole with neon indicator Compliances RoHS; WEEE; CE; UKCA